



## Aquatera Service Connection Procedure

### Step 1: Submit a Service Connection Application.

The applicant is responsible for determining the line sizes required for development, and they should either meet or exceed the below minimum requirements (not including fire lines).

Development	Water Size	Sewer Size
Residential	19mm	100mm
Commercial	25mm	150mm
Industrial	25mm	150mm

Note: The infrastructure charge increases proportionally with an increase in water size.

**Step 2:** Within 10 working days of the completed application, Aquatera will provide a quote to complete the work in accordance with the service drawing, including all restoration and engineering fees.

The applicant must provide payment to Aquatera for the amount of the total estimated cost before the work can proceed.

The applicant will be responsible for notifying Aquatera of any changes to the servicing drawings or site conditions.

All restoration will be completed by Aquatera in accordance with municipality's standards and specifications and form part of the estimated cost of construction.

Additional costs will be invoiced for extra work related to changes to servicing drawings, site conditions, frost excavation and unforeseeable circumstances.

The connection from to the property line to the building is the responsibility of the applicant and may only take place following completion of the public portion by Aquatera, unless otherwise approved.

For any questions, please contact our engineering team at [devengineering@aquatera.ca](mailto:devengineering@aquatera.ca)